

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for City of Kamiah

Our water system recently violated a drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

**We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. This annual certification of the product used was late, however the actual dosage was limited to about 4.5% of the maximum permissible and then only during the colder part of the year when the water temperature is less than 10 degrees C. Kamiah's water remained way under the level of concern even during the maximum usage period. Maximum permissible product dose is 1 part per million, ours was .045 PPM.*

What should I do?

There is nothing you need to do at this time.

The table below lists the contaminant(s) we did not properly test for, how often we are supposed to sample for [this contaminant/these contaminants] and how many samples we are supposed to take, how many samples we took, when samples should have been taken, and the date on which follow-up samples were (or will be) taken.

Contaminant	Required sampling frequency	Number of samples taken	When calculation should have been made	When calculation was made
Acrylamide and Epichlorohydrin	One certification annually	Not applicable: dosage calculation required, not samples	In 2025	April 2026

What is being done?

Calculation taken during peak use period, since reported to DEQ as required.

For more information, please contact Stuart Bryant at 208-935-0319 or PO Box 338, Kamiah ID. 83536.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by the City of Kamiah, State Water System ID#:2310003.

Date distributed April 17, 2026