

# Kamiah 2020 Consumer Confidence Report

## **Is my water safe?**

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies. Last year, we conducted tests for several contaminants. The only one which exceeded the stringent EPA regulations was an excess lead level at just two sites. As we informed you at the time, our water temporarily exceeded drinking water standards. (For more information see the section labeled Violations at the end of the report.)

## **Do I need to take special precautions?**

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

## **Where does my water come from?**

Kamiah's water treatment plant is fed by a surface water source, the Clearwater River.

## **Source water assessment and its availability**

Information regarding our Source Water Assessment can be found here:

<http://www2.deq.idaho.gov/water/swaOnline/Search>

Select "Kamiah, City of", and be sure to select "Clearwater River New" as the source.

## **Why are there contaminants in my drinking water?**

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791).

## **For more information**

Please visit our city website at <https://cityofkamiah.org/> and visit our FAQ under the Residents tab in the Public Works section. If you have questions or concerns please feel free to contact us via our website's Contact Us tab. Responses are usually given within 24 hours weekdays. For more urgent matters please contact City Hall at 208-935-2672.

## **Description of Water Treatment Process**

Your water is treated by filtration and disinfection. Filtration removes particles suspended in the source water. Particles typically include clays and silts, natural organic matter, iron and manganese, and microorganisms. Your water is also treated by disinfection. Disinfection involves the addition of chlorine or other disinfectants to kill bacteria and other microorganisms (viruses, cysts, etc.) that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

## **Water Conservation Tips**

Did you know that the average U.S. household uses approximately 400 gallons of water per day or 100 gallons per person per day? Luckily, there are many low-cost and no-cost ways to conserve water. Small changes can make a big difference - try one today and soon it will become second nature.

- Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath.

- Shut off water while brushing your teeth, washing your hair and shaving and save up to 500 gallons a month.
- Use a water-efficient showerhead. They're inexpensive, easy to install, and can save you up to 750 gallons a month.
- Run your clothes washer and dishwasher only when they are full. You can save up to 1,000 gallons a month.
- Water plants only when necessary.
- Fix leaky toilets and faucets. Faucet washers are inexpensive and take only a few minutes to replace. To check your toilet for a leak, place a few drops of food coloring in the tank and wait. If it seeps into the toilet bowl without flushing, you have a leak. Fixing it or replacing it with a new, more efficient model can save up to 1,000 gallons a month.
- Adjust sprinklers so only your lawn is watered. Apply water only as fast as the soil can absorb it and during the cooler parts of the day to reduce evaporation.
- Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!
- Visit [www.epa.gov/watersense](http://www.epa.gov/watersense) for more information.

### **Source Water Protection Tips**

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

### **Additional Information for Lead**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. City of Kamiah is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Kamiah is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

---

## Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
<b>Disinfectants &amp; Disinfection By-Products</b>								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Haloacetic Acids (HAA5) (ppb)	NA	60	22.1	15.3	22.1	2020	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	17	6.13	17	2020	No	By-product of drinking water disinfection
<b>Inorganic Contaminants</b>								
Barium (ppm)	2	2	.059	NA	NA	2016	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
<b>Microbiological Contaminants</b>								
Turbidity (NTU)	NA	0.3	100	NA	NA	2020	No	Soil runoff
100% of the samples were below the TT value of .3. A value less than 95% constitutes a TT violation. The highest single measurement was .094. Any measurement in excess of 1 is a violation unless otherwise approved by the state.								
<b>Radioactive Contaminants</b>								
Alpha emitters (pCi/L)	0	15	.446	NA	NA	2016	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	1.212	NA	NA	2019	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
<b>Inorganic Contaminants</b>								
Copper - action level at consumer taps (ppm)	1.3	1.3	.198	2020	0	No	Corrosion of household plumbing systems; Erosion of natural deposits.	
Lead - action level at consumer taps (ppb)	0	15	25.95	2020	2	Yes	Corrosion of household plumbing systems; Erosion of natural deposits. The Clearwater River has not been found to be a significant contributor.	

<b>Violations and Exceedances</b>
<p><b>Lead - action level at consumer taps</b></p> <p>Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. The exceedance occurred at two sites on Sept. 22, 2020. The water plant further increased the outgoing pH, then implemented increased monitoring from ten samples per year to forty. A corrosion control study was implemented with oversight by Idaho Department of Environmental Health and facilitated by staff from the Mountain Waterworks engineering firm and personnel from the University of Idaho. This study identified the probable best path for</p>

<b>Violations and Exceedances</b>
correction which will be verified in the coming months in the continuation of the study. The City of Kamiah is expecting to be able to dose a mineral compound naturally occurring in most rivers to make up for the the Clearwater River's excessive ability to dissolve even trace amounts of metals thanks to it exceptional purity. A full round of 20 samples has already been completed in 2021, and we are within our required 90th percentile so far this year.

<b>Unit Descriptions</b>	
<b>Term</b>	<b>Definition</b>
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NTU	NTU: Nephelometric Turbidity Units. Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system.
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

<b>Important Drinking Water Definitions</b>	
<b>Term</b>	<b>Definition</b>
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level

**For more information please contact:**

Contact Name: Stuart Bryant  
Address: PO Box 338  
Kamiah, ID 83536  
Phone: 208-935-0319